



Jamshedpur Notified Area Committee, Jamshedpur



New Kalimati Road, Sakchi-831001

E- mail ID-jnacjsr@gmail.com

Letter no: 1534.....

Date: 22/05/2026.....

Certificate for Safe Drinking Water & Sanitary Condition


It is certified that an inspection team headed by Mr. Jyoti Punj City Manager from Sanitation department, Jamshedpur Notified Area Committee inspected the D.B.M.S KADMA HIGH SCHOOL, JAMSHEDPUR on 01/04/2026 and found that D.B.M.S KADMA HIGH SCHOOL, JAMSHEDPUR, has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above valid for a period, 01/04/2026 To 31/03/2027


22/05/2026


F/S Inspector

Jamshedpur Notified Area Committee,
Jamshedpur.



City Manager,

Jamshedpur Notified Area Committee,
Jamshedpur.




Special Officer,

Jamshedpur Notified Area Committee,
Jamshedpur.

To,

D.B.M.S KADMA HIGH SCHOOL
KADMA, JAMSHEDPUR.





To,
DBMS KADMA HIGH SCHOOL.
Road no -23, Farm Area
KADMA

WMD/LAB/TL-35/ 81 /26

Date: 5-05-2026

Sub : Drinking Water Quality of your Institution

Dear Sir/Madam


Water samples were received on 29/04/2026 for analysis of the water quality at our laboratory. The water quality was found to be **Satisfactory**. Chemical & Bacteriological analysis report is appended below.

Chemical & Bacteriological analysis report.

Sl. No.	Parameters	Source	Standards / Norms	
		Inlet water	World Health Organization (WHO)	Bureau of Indian Standards (BIS)
1	Turbidity (NTU)	1.3	≤ 1.0	≤ 1.0 (Acceptable) ≤ 5.0 (Permissible)
2	pH	7.4	6.5-8.5	6.5-8.5
3	Free chlorine(mg/l)	0.2	≥ 0.2	≥ 0.2
4	Total Coliforms/100ml	Absent	Absent	Absent
5	E. coli/100ml	Absent	Absent	Absent

Thank you and always assure you our best services.

Yours Sincerely,


Manager/Dy. Manager
Town Laboratory, Waterworks.
Water & Wastewater Services.

TATA STEEL UTILITIES AND INFRASTRUCTURE SERVICES LIMITED

(Formerly Jamshedpur Utilities & Services Company Limited)

Registered Office Sakchi Boulevard Road Northern Town Bistupur Jamshedpur 831 001 India

Tel 91 657 6652101 Fax 91 657 2424219

Corporate Identity Number U45200JH2003PLC010315

Website www.tatasteeluisi.com


Gurpreet Bhambra
Principal

DBMS Kadma High School


Anita Ramkrishna
Hony Secretary

DBMS Kadma High School

